

MODEL SPECIFICATION FOR CORGAL TANK - 30 DEGREE ROOF

CORRUGATED, GALVANIZED STEEL WATER STORAGE TANK

The water storage tank shall be a CorGal Model **0605-WT-FS** or equal with standard 30 degree flat-seam roof having a nominal capacity of **3,700** US gallons.

Nominal tank dimensions shall be 6'-0" diameter, 17'-11" eave height, and 19'-4" overall height.

The water storage tank shall be designed to store water with a density of 62.4 PCF in a seismic zone 2B with a wind speed of 90 MPH, UBC Exposure C.

The tank structure shall consist of corrugated galvanized steel wall sheets, flat-seam galvanized steel roof panels, standard roof peak access and cap, anchor clips and necessary hardware for tank assembly.

All steel panel material shall be galvanized to meet the G-115 galvanizing standard.

Bolts shall be heat treated to grade SAE 8.2 and electro-galvanized with JS-500 clear coating.

Roof bolts shall have factory installed, steel-backed vinyl washers.

Wall bolts shall have slotted button heads for insertion from inside the tank toward outside.

Water containment system shall consist of liner hanger brackets, a geo-textile pre-liner installed on the foundation and the interior of the walls and a 25 mil. PVC factory welded seam, flexible membrane main liner.

The water tank shall be constructed on a concrete foundation as designed and installed by others.